

CERTIFICATE

Issued to:
Applicant:
WISKA Hoppmann GmbH
Kisdorfer Weg 28
24568 Kaltenkirchen, Germany

Manufacturer/Licensee:
WISKA Hoppmann GmbH
Kisdorfer Weg 28
24568 Kaltenkirchen, Germany

Product : Connection box for fixed electrical installation
Trade name(s) : WISKA
Type(s)/model(s) : WHK608A and WHK608S

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60670-1:2005, EN 60670-1:2005/A1:2013 and EN 60670-22:2006
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900947

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 6 June 2017 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-100039

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



Henk Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Connection box for fixed electrical installation
Trade name(s)	: WISKA
Type(s)/model(s)	: WHK608A and WHK608S
Rated insulation voltage	: 400 V~
Material	: polystyrol (grey)
Methode of installaiton	: surface mounting
Nature of installation	: on wall non-combustible- and combustible solids after building
Degree of protection	: IP20
Dimensions	: rectangular box 108 x 98 mm
Rated connecting capacity	: 4,0 mm ²
May be equipped with	: connecting devices with screw / screwless clamping units

Product data – type WHK608A

Body	: suitable for 8 inlets
Cover	: plain cover

Product data – type WHK608S

Body	: suitable for 8 inlets
Cover	: suitable for several contacts

TESTS**Test requirements**

EN 60670-1:2005
EN 60670-1:2005/A1:2013
EN 60670-22:2006

Test result

The test results are laid down in DEKRA test file 221399200.

Additional Information

This KEMA-KEUR certificate is based on the result of VDE number CCA / DE1 34560 with TRF No. 227812-CC3-1.

This certificate replaces certificate No. 2213992.01 which we herewith declare invalid.

Conclusion

The examination proved that all requirements were met.

Factory location

WISKA Hoppmann GmbH
Kisdorfer Weg 28
24568 Kaltenkirchen, Germany