

产品认证证书

II型自愿认证

证书编号: CQC2004010304138319

发证日期: 2020年08月21日

有效期至: 2032年06月17日

委托人名称	ABB France
及注册地址	2 rue d'Arsonval 69680 Chassieu France
制造商名称	ABB France
及注册地址	2 rue d'Arsonval 69680 Chassieu France
生产企业名称	ABB France
及生产地址	2 rue d'Arsonval 69680 Chassieu France
产品名称和系列、 规格、型号	切换电容器接触器 UA16-30...RA Ui : 1000V ; Ith : 30A ; AC-6b : Ue/Ie : AC220/230/240/400/415/440/500/550/660/690V/21A ; Us : 24V 50/60Hz , 110V 50Hz/110-120V 60Hz , 220-230V 50Hz/230-240V 60Hz , 380-400V 50Hz/400-415V 60Hz ; 极数 : 3P ; 配用辅助触头 : (本体) 1NO Ith : 16A ; AC-15 : Ue/Ie : 24-127V/6A , 220-240V/4A , 380-440V/3A , 500-690V/2A ; DC-13 : Ue/Ie : 24V/6A , 48V/2.8A , 72V/2A , 110-125V/1.1A , 220-250V/0.55A
产品标准和技术要求	GB/T 14048.4-2010
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

郑喆

签发

谢肇煦

中国质量认证中心



CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2004010304138319

Valid from: Aug.21,2020

Valid until: Jun.17,2032

NAME AND REGISTERED ADDRESS OF THE APPLICANT ABB France
2 rue d'Arsonval 69680 Chassieu France

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER ABB France
2 rue d'Arsonval 69680 Chassieu France

NAME AND LOCATION OF THE FACTORY ABB France
2 rue d'Arsonval 69680 Chassieu France

PRODUCT NAME, MODEL AND SPECIFICATION Contactors for capacitor switching
UA16-30...RA Ui : 1000V ; Ith : 30A ; AC-6b : Ue/Ie :
AC220/230/240/400/415/440/500/550/660/690V/21A ; Us :24V 50/60Hz ,110V 50Hz/110-120V
60Hz , 220-230V 50Hz/230-240V 60Hz ,380-400V 50Hz/400-415V 60Hz ; Poles :3P ; Attached
Auxiliary Contacts: 1NO;Ith : 16A ; AC-15 : Ue/Ie : 24-127V/6A , 220-240V/4A , 380-440V/3A ,
500-690V/2A ; DC-13 : Ue/Ie : 24V/6A , 48V/2.8A , 72V/2A , 110-125V/1.1A , 220-250V/0.55A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.4-2010

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

郑士泉

SIGNATURE

谢肇煦

CHINA QUALITY CERTIFICATION CENTRE

